

AS/NZS 4020:2018 Compliance Testing
Certificate of Conformance
 (Summary of Certificate of Analysis)
 Dated: 20/04/2022

The product, **PABCO Premier® Algae Defender™, Asphalt Shingle Roofing**; was supplied by **Asphalt Shingle Roofing Supplies Ltd. (515A Mt Wellington Highway, Mt Wellington, Auckland)** on **09/12/2021** for compliance testing to AS/NZS 4020:2005, Testing of products for use in contact with drinking water. All tests were completed and evaluated on **13/04/2022**. Certificate of Analysis Reference No¹. **NJ21AB5578-1**, is a detailed report on all tests conducted on samples of this product.

Based on completion and evaluation of all tests on 13/04/2022, the product, PABCO Premier® Algae Defender™; fully complied with the test requirements of AS/NZS 4020:2018 to cover a cold water application up to <40°C, at the recommended 'total immersion' exposure of ~30,000mm² PABCO Premier® Algae Defender™ / 1L test water at (20 ± 2)°C.

Testing although determined by the relevant product Standard, is generally recognised for up to 5 years by the certifying body, providing the testing procedures remain the same and the background information on the product is adequately documented. Also, the results stated in the report relate to the samples of the product submitted for testing. Any changes in the material formulation and supplier/manufacturer of all ingredients, the process of manufacture, the method of application, or the surface area-to-volume ratio in the end-use, could affect the suitability of the product for use in contact with drinking water, and re-testing may be required before this actual time frame, governed by the completion and evaluation date.

Signed:



SANDHYA L. SINGH B. Tech, Postgrad. Dip. (Chem)
 Manager, Chemistry and Toxicology; Approved Signatory

 Date: 20/04/2022

¹ **NOTE: For product Certification, the Certificate of Conformance must be distributed with the relevant Certificate of Analysis and Attachments.**

THIS CONFORMANCE SUMMARY MUST NOT BE REPRODUCED EXCEPT IN FULL
 Page 1 of 1